



QUALITY TEST CERTIFICATION

Alloy No: C12200 Temper: O60

Dimension: $\Phi 5/8" \times 0.66 \times 15M$

Specification: ASTM B280

Test Items		Normal Value	Test Value	
			Sample 1	Result
Size	(OD) mm	15.88±0.05	15.91	Pass
	(Wall thickness) mm	0.66(-0.06~+0.02)	0.62-0.67	Pass
	(Grain Size) mm	≥ 0.040	0.040	Pass
	(Clearness) mg/m ²	≤ 38	20.33	Pass
Mechanical Property	Tensile Strength Mpa	≥ 205	247	Pass
	Elongation %	≥ 40	48.5	Pass
Expansion Test $\alpha=60^\circ$ D=1.4D		No crack when vision	Pass	Pass
Eddy Current Test mm		0Point	Pass	Pass
Surface		Conform To		
Packing Requirement		Conform To		
Marking		Conform To		
% Chemical Composition	Cu	≥99.90	99.96	Pass
	P	0.015-0.040	0.0335	Pass
RESULT	PASS			

This Product is Certified to be in accordance with the specification.