

SUPERFRIO

REFRIGERANT



TOTAL INGENIEROS S.A.C
VENTAS, PROYECTOS, SERVICIOS EN INGENIERIA Y SISTEMAS DE REFRIGERACION

R404A CERTIFICATE OF ANYLYSIS

R404A CERTIFICATE OF QUALITY

10.9kg/.NW

Density items	Standard demands	Results
Appearance	Colourless and not turbid	Colourless and not turbid
Purity,%	≥99.5	99.93
HFC-143a,%	52±1	52.2
HFC-125,%	44±2	44.0
HFC-134a,%	4±2	4.0
Moisture%	≤0.001	0.00094
Non-condensable gases	≤1.5	0.1
Acidity (as HCl) %	≤0.0001	<0.0001
Evaporation residue%	≤0.01	0.0008
Product amount:	Final conclusion: Conformity	

GRADE : FIRST-CLASS PRODUCT

Inspector: 07

Review13

Check: 09